



This page was intentionally left blank

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	3 of <a href="#">27</a>

#### Change record

Issue/Rev.	Date	Section/Parag. affected	Reason/Initiation/Documents/Remarks
1.0	21/10/18	All	First release

This page was intentionally left blank

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	5 of 27

## Contents

<b>1</b>	<b>Introduction And Scope</b>	<b>7</b>
<b>2</b>	<b>Software Installation</b>	<b>8</b>
<b>3</b>	<b>Demo Data</b>	<b>9</b>
<b>4</b>	<b>Quick Start: Reducing The Demo Data</b>	<b>10</b>
<b>5</b>	<b>About The Reflex Canvas</b>	<b>14</b>
5.1	Saving And Loading Workflows . . . . .	14
5.2	Buttons . . . . .	14
5.3	Workflow States . . . . .	14
<b>6</b>	<b>The SINFONI Workflow</b>	<b>15</b>
6.1	Workflow Canvas Parameters . . . . .	15
6.2	Workflow Actors . . . . .	16
6.2.1	Simple Actors . . . . .	16
6.2.2	Composite Actors . . . . .	16
6.2.3	Recipe Execution within Composite Actors . . . . .	16
6.2.4	Lazy Mode . . . . .	18
6.3	Workflow Steps . . . . .	19
6.3.1	Step 1: Data Organisation And Selection . . . . .	19
6.3.2	Step 2: Recipe execution . . . . .	21
6.3.3	Step 3: Final products . . . . .	21
<b>7</b>	<b>Troubleshooting</b>	<b>24</b>
<b>8</b>	<b>Frequently Asked Questions</b>	<b>25</b>

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	6 of 27

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	7 of 27

## 1 Introduction And Scope

Reflex is the ESO Recipe Flexible Execution Workbench, an environment to run ESO VLT pipelines which employs a workflow engine (Kepler<sup>1</sup>) to provide a real-time visual representation of a data reduction cascade, called a workflow, which can be easily understood by most astronomers. The basic philosophy and concepts of Reflex have been discussed by Freudling et al. (2013, A&A in press). Please reference this article if you use Reflex for your research.

Reflex and the data reduction workflows have been developed at ESO and they are fully supported. If you have any issue, please contact [usd-help@eso.org](mailto:usd-help@eso.org) for further support.

This document is a tutorial designed to enable the user to employ the SINFONI workflow to reduce his/her data in a user-friendly way, concentrating on high-level issues such as data reduction quality and signal-to-noise (S/N) optimisation.

A workflow accepts science and calibration data, as delivered to PIs in the form of PI-Packs (until October 2011) or downloaded from the archive using the CalSelector tool<sup>2</sup> and organises them into DataSets, where each DataSet contains one science object observation (possibly consisting of several science files) and all associated raw and static calibrations required for a successful data reduction. The data organisation process is fully automatic, which is a major time-saving feature provided by the software. The DataSets selected by the user for reduction are fed to the workflow which executes the relevant pipeline recipes (or stages) in the correct order. Full control of the various recipe parameters is available within the workflow, and the workflow deals automatically with optional recipe inputs via built-in conditional branches. Additionally, the workflow stores the reduced final data products in a logically organised directory structure employing user-configurable file names.

This tutorial deals with the reduction of SINFONI Integral Field Unit observations only via the SINFONI workflow. The user is referred to the SINFONI web page (<http://www.eso.org/sci/facilities/paranal/instruments/sinfoni/>) for more information on the instrument itself, and the SINFONI pipeline user manual for the details of the pipeline recipes (<http://www.eso.org/sci/software/pipelines/>).

The workflow uses association rules known to work with files downloaded from the ESO archive with the CalSelector tool (from year 2009 onwards). For older datasets where the data were directly delivered to the PI (e.g. in DVDs) see 7.

---

<sup>1</sup><http://kepler-project.org>

<sup>2</sup><http://www.eso.org/sci/archive/calselectorInfo.html>

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	8 of 27

## 2 Software Installation

The software pre-requisites for Reflex 2.5 may be found at:

[http://www.eso.org/sci/software/pipelines/reflex\\_workflows](http://www.eso.org/sci/software/pipelines/reflex_workflows)

To install the Reflex 2.5 software and demo data, please follow these instructions:

1. From any directory, download the installation script:

```
wget ftp://ftp.eso.org/pub/dfs/reflex/install_reflex
```

2. Make the installation script executable:

```
chmod u+x install_reflex
```

3. Execute the installation script:

```
./install_reflex
```

and the script will ask you to specify three directories: the download directory <download\_dir>, the software installation directory <install\_dir>, and the directory to be used to store the demo data <data\_dir>. If you do not specify these directories, then the installation script will create them in the current directory with default names.

4. You will be given a choice of pipelines (with the corresponding workflows) to install. Please specify the numbers for the pipelines you require, separated by a space, or type “A” for all pipelines.
5. To start Reflex, issue the command:

```
<install_dir>/bin/reflex
```

It may also be desirable to set up an alias command for starting the Reflex software, using the shell command `alias`. Alternatively, the `PATH` variable can be updated to contain the <install\_dir>/bin directory.



<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	9 of 27

### 3 Demo Data

Together with the pipeline you will also receive a demo data set, that allows you to run the `Reflex SINFONI` workflow without any changes in parameters. This way you have a data set to experiment with before you start to work on your own data. The demo data for SINFONI includes example data for the workflow.

Note that you will need a minimum of  $\sim 2.0$  GB,  $\sim 0.6$  GB and  $\sim 3.8$  GB of free disk space for the directories `<download_dir>`, `<install_dir>` and `<data_dir>`, respectively. The SINFONI demo data have been retrieved with the CalSelector tool<sup>3</sup>.

---

<sup>3</sup><http://www.eso.org/sci/archive/calselectorInfo.html>

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	10 of 27

## 4 Quick Start: Reducing The Demo Data

For the user who is keen on starting reductions without being distracted by detailed documentation, we describe the steps to be performed to reduce the science data provided in the SINFONI demo data set supplied with the Reflex 2.5 release. By following these steps, the user should have enough information to attempt a reduction of his/her own data without any further reading:




Figure 4.0.1: *The empty Reflex canvas.*

1. Start the Reflex application:


```
reflex &
```

The empty Reflex canvas as shown in Figure 4.0.1 will appear.

2. Now open the SINFONI workflow by clicking on **File** -> **Open File**, selecting first `sinfo-2.4.0` and then the file `sinfo.xml` in the file browser. You will be presented with the workflow canvas shown in Figure 4.0.2. Note that the workflow will appear as a canvas in a new window.
3. To aid in the visual tracking of the reduction cascade, it is advisable to use component (or actor) highlighting. Click on **Tools** -> **Animate at Runtime**, enter the number of milliseconds representing the animation interval (100 ms is recommended), and click **OK**.
4. Under “Setup Directories” in the workflow canvas there are seven parameters that specify important directories (green dots). Setting the value of `ROOT_DATA_DIR` is the only necessary modification if you want to process data other than the demo data<sup>4</sup>, since the value of this parameter specifies the working directory within which the other directories are organised. Double-click on the parameter `ROOT_DATA_DIR` and a pop-up window will appear allowing you to modify the directory string, which you may either edit directly, or use the **Browse** button to select the directory from a file browser. When you have finished, click **OK** to save your changes.

<sup>4</sup>If you used the install script `install_reflex`, then the value of the parameter `ROOT_DATA_DIR` will already be set correctly to the directory where the demo data was downloaded.

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	11 of 27

5. Click the  button to start the workflow
6. The workflow will highlight the `Data Organiser` actor which recursively scans the raw data directory (specified by the parameter `RAWDATA_DIR` under “Setup Directories” in the workflow canvas) and constructs the `DataSets`. Note that the raw and static calibration data must be present either in `RAWDATA_DIR` or in `CALIB_DATA_DIR`, otherwise `DataSets` may be incomplete and cannot be processed. However, if the same reference file was downloaded twice in different places this creates a problem as `Reflex` cannot decide which one to use.
7. The `Data Set Chooser` actor will be highlighted next and will display a “Select Datasets” window (see Figure 4.0.3) that lists the `DataSets` along with the values of a selection of useful header keywords<sup>5</sup>. The first column consists of a set of tick boxes which allow the user to select the `DataSets` to be processed, and by default all complete `DataSets` are selected.
8. Click the `Continue` button and watch the progress of the workflow by following the red highlighting of the actors. A window will show which `DataSet` is currently being processed.
9. When the reduction of the current `DataSet` finishes, a pop-up window called *Provenance Explorer* will appear showing the datasets which have been so far reduced together with the list of final products. This actor allows the user to inspect the final data products, as well as to search and inspect the input data used to create any of the products of the workflow. Figure 4.0.4 shows the *Provenance Explorer* window.
10. The workflow will continue with the remaining `DataSets` following the same steps described above.
11. After the workflow has finished, all the products from all the `DataSets` can be found in a directory under `END_PRODUCTS_DIR` with the named with the workflow start timestamp. Further subdirectories will be found with the name of each `DataSet`.

Well done! You have successfully completed the quick start section and you should be able to use this knowledge to reduce your own data. However, there are many interesting features of `Reflex` and the `SINFONI` workflow that merit a look at the rest of this tutorial.

---

<sup>5</sup>The keywords listed can be changed by right-clicking on the `DataOrganiser Actor`, selecting `Configure Actor`, and then changing the list of keywords in the second line of the pop-up window.




Figure 4.0.2: *SINFONI workflow general layout.*

Selected	Data Set	#Files	OBJECT	INS. GRAT.	INS. OP.
<input checked="" type="checkbox"/>	SINFO 2011-01-02T02:33:52.141.tpi	126	SN-1987A	K	0.1
<input checked="" type="checkbox"/>	SINFO 2011-01-02T03:22:47.486.tpi	124	STD	K	0.1
<input checked="" type="checkbox"/>	SINFO 2011-01-02T03:41:17.871.tpi	126	SN-1987A	K	0.1
<input checked="" type="checkbox"/>	SINFO 2011-01-02T04:29:38.152.tpi	124	STD	K	0.1
<input checked="" type="checkbox"/>	SINFO 2011-01-02T07:30:28.238.tpi	125	PSF-CALIBRATOR	K	0.1
<input checked="" type="checkbox"/>	SINFO 2011-01-02T08:46:36.871.tpi	124	STD	K	0.1

Select complete

Select all

Deselect all

Save all

Inspect highlighted

Continue

Stop

Figure 4.0.3: *The “Select Datasets” pop-up window.*

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	13 of 27




Figure 4.0.4: The Provenance Explorer shows all datasets reduced in previous executions together with the full reduction chain for all the pipeline products.

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	14 of 27








## 5 About The Reflex Canvas

### 5.1 Saving And Loading Workflows

In the course of your data reductions, it is likely that you will customise the workflow for various data sets, even if this simply consists of editing the `ROOT_DATA_DIR` to a different value for each data set. Whenever you modify a workflow in any way, you have the option of saving the modified version to an XML file using `File -> Export As` (which will also open a new workflow canvas corresponding to the saved file). The saved workflow may be opened in subsequent Reflex sessions using `File -> Open`. Saving the workflow in the default format (.kar) is only advised if you do not plan to use the workflow in another computer.









### 5.2 Buttons

At the top of the Reflex canvas are a set of buttons which have the following useful functions:

-  - Zoom in.
-  - Reset the zoom to 100%.
-  - Zoom the workflow to fit the current window size (Recommended).
-  - Zoom out.
-  - Run (or resume) the workflow.
-  - Pause the workflow execution.
-  - Stop the workflow execution.

The remainder of the buttons (not shown here) are not relevant to the workflow execution.

### 5.3 Workflow States

A workflow may only be in one of three states: executing, paused, or stopped. These states are indicated by the yellow highlighting of the , , and  buttons, respectively. A workflow is executed by clicking the  button. Subsequently the workflow and any running pipeline recipe may be stopped immediately by clicking the  button, or the workflow may be paused by clicking the  button which will allow the current actor/recipe to finish execution before the workflow is actually paused. Note that after clicking the  button, it is possible that more than one actor is executed, since this behaviour depends on the workflow scheduling. For instance, if there are two actors in parallel, and you pause the workflow while one is being executed, then both of them will be executed before the workflow is actually paused. After pausing, the workflow may be resumed by clicking the  button again.

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	15 of 27

## 6 The SINFONI Workflow

The SINFONI workflow canvas is organised into a number of areas. From top-left to top-right you will find general workflow instructions, directory parameters, and global parameters. In the middle row you will find five boxes describing the workflow general processing steps in order from left to right, and below this the workflow actors themselves are organised following the workflow general steps.

### 6.1 Workflow Canvas Parameters

The workflow canvas displays a number of parameters that may be set by the user. Under “Setup Directories” the user is only required to set the `RAWDATA_DIR` to the working directory for the `DataSet(s)` to be reduced, which, by default, is set to the directory containing the demo data. The `RAWDATA_DIR` is recursively scanned by the `Data Organiser` actor for input raw data. The directory `CALIB_DATA_DIR`, which is by default within the pipeline installation directory, is also scanned by the `Data Organiser` actor to find any static calibrations that may be missing in your `DataSet(s)`. If required, the user may edit the directories `BOOKKEEPING_DIR`, `LOGS_DIR`, `TMP_PRODUCTS_DIR`, and `END_PRODUCTS_DIR`, which correspond to the directories where book-keeping files, logs, temporary products and end products are stored, respectively (see the Reflex User Manual for further details; [Forchi \(2012\)](#)).

Under the “Global Parameters” area of the workflow canvas, the user may set the `FITS_VIEWER` parameter to the command used for running his/her favourite application for inspecting FITS files. Currently this is set by default to `fv`, but other applications, such as `ds9`, `skycat` and `gaia` for example, may be useful for inspecting image data.

By default the `EraseDirs` parameter is set to `false`, which means that no directories are cleaned before executing the workflow, and the recipe actors will work in Lazy mode (see Section 6.2.4), reusing the previous pipeline recipe outputs where input files and parameters are the same as for the previous execution, which saves considerable processing time. Sometimes it is desirable to set the `EraseDirs` parameter to `true`, which forces the workflow to recursively delete the contents of the directories specified by `BOOKKEEPING_DIR`, `LOGS_DIR`, and `TMP_PRODUCTS_DIR`. This is useful for keeping disk space usage to a minimum and will force the workflow to fully rereduce the data each time the workflow is run.

The parameter `RecipeFailureMode` controls the behaviour in case that a recipe fails. If set to `Continue`, the workflow will trigger the next recipes as usual, but without the output of the failing recipe, which in most of the cases will lead to further fails of other recipes without the user actually realising of it. This mode might be useful for unattended processing of large number of datasets. If set to `Ask`, a pop-up window will ask whether the workflow should stop or continue. This is the default. Additionally, the `Stop` mode will stop the workflow execution immediately.

The parameter `GlobalInteractivity` controls whether the interactive windows will appear for those windows which are *enabled* by default. The possible values are `true`, `false`. Take into account that some windows are disabled in the default configuration and therefore are not affected by this parameter.






The parameter `ProvenanceExplorerEnabled` controls whether the `ProvenanceExplorer` actor will show its window or not. The possible values are `true`, `false`.

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	16 of 27

## 6.2 Workflow Actors

### 6.2.1 Simple Actors

Simple actors have workflow symbols that consist of a single (rather than multiple) green-blue rectangle. They may also have a logo within the rectangle to aid in their identification. The following actors are simple actors:

-  - The Data Organiser actor.
-  - The Data Set Chooser actor.
-  - The Fits Router actor
-  - The Product Renamer actor.
-  - The Provenance Explorer actor.

Access to the parameters for a simple actor is achieved by right-clicking on the actor and selecting `Configure Actor`. This will open an “Edit parameters” window. Note that the `Product Renamer` actor is a jython script (Java implementation of the Python interpreter) meant to be customised by the user (by double-clicking on it).

### 6.2.2 Composite Actors

Composite Actors have workflow symbols that consist of multiply-layered green-blue rectangles. They generally do not have a logo within the rectangle. A Composite Actor represents a combination of more Simple or Composite Actors which hides over-complexity from the user in the top-level workflow.

Composite Actors may also be expanded for inspection. To do this, right-click on the actor and select `Open Actor`, which will expand the Composite Actor components in a new `Reflex` canvas window. If the Composite Actor corresponds to a pipeline recipe, then the corresponding `RecipeExecutor` actor will be present as a Simple Actor, and its parameters are accessible as for any other Simple Actor. Alternatively you may still find Composite Actors, on which you need to repeat the first step to access the `Recipe Executor`.

### 6.2.3 Recipe Execution within Composite Actors

The SINFONI workflow contains Composite Actors to run pipeline recipes. This is in the most simple case due to the `SoF Splitter/SoF Accumulator`<sup>6</sup>, which allow to process calibration data from different

<sup>6</sup>SoF stands for Set of Files, which is an ASCII file containing the name (and path) of each input file and its category (e.g. `FLAT`).



ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	17 of 27

setting within one given DataSet (e.g. lamp frames taken with different preoptics/band-filters). More complex Composite Actors contain several actors (e.g. Recipe Executer).




Figure 6.2.1: This is the window you get when you choose Open Actor for the Composite Actor Master Flat Computation. This is the most simple case for a Composite Actor. Using Configure Actor on `sinfo_rec_mflat_1` gives you Fig. 6.2.2.

The central elements of any Reflex workflow are the `RecipeExecuter` actors that actually run the recipes. One basic way to embed a `RecipeExecuter` in a workflow is shown in Fig 6.2.1, which is the most simple version of a Composite Actor. The `RecipeExecuter` is preceded by an `SofSplitter`, and followed by an `SofAccumulator`. The function of the `SofSplitter` is to investigate the incoming SoFs, sort them by “purpose”, and create separate SoFs for each purpose. The `RecipeExecuter` then processes each of the SoFs independently (unless they are actually the same files). Finally, the `SofAccumulator` packs all the results into a single output SoF. The direct relation between the `SofSplitter` and `SofAccumulator` is used to communicate the number of different SoFs created by the `SofSplitter`. A workflow will only work as intended if the purpose of all the files a recipe needs as input is identical. The only exception to this rule is that a purpose can also be “default”. In this case, the file is included in any output SoF created by the `SofSplitter` and `SofAccumulator`.

The reason for this scheme is best explained by an example. For a complex DataSet, the Data Organiser might have selected a large number of individual raw lamp frames (arc and flat field). The different lamp frames are to be used to calibrate different frames, e.g. the science frames and the standard star frames. The Data Organiser determines and records this “purpose” of each lamp frame, and this information is included in the DataSet and each SoF created from this DataSet. The `FitsRouter` directs all raw lamp frames to the calibration Composite Actor. The `SofSplitter` then creates SoFs, one for the lamp frames to be used for the science frames, and (probably) separate ones for the lamp frames to be used for the standard star observations. The calibration recipe creates one master flat field (and other products) for each SoF, and the `SofAccumulator` then creates a SoF that contains all the products.

A `RecipeExecuter` actor is used in the workflow to run a single SINFONI pipeline recipe (e.g: in the Master Flat Computation actor the recipe `sinfo_rec_mflat` is executed). In order to configure the `RecipeExecuters`, one has to first use Open Actor to get to the level of the recipe executors (see Fig. 6.2.1).

In Figure 6.2.2 we show the “Edit parameters” window for a typical `RecipeExecuter` actor, which can be displayed by right-clicking on the actor and selecting Configure Actor. In the following we describe in more detail the function of some of the parameters for a `RecipeExecuter` actor:

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	18 of 27

- The “recipe” parameter states the SINFONI pipeline recipe which will be executed.
- The “mode” parameter has a pull-down menu allowing the user to specify the execution mode of the actor. The available options are:
  - Run: The pipeline recipe will be executed, possibly in Lazy mode (see Section 6.2.4). This option is the default option.
  - Skip: The pipeline recipe is not executed, and the actor inputs are passed to the actor outputs.
  - Disabled: The pipeline recipe is not executed, and the actor inputs are not passed to the actor outputs.
- The “Lazy Mode” parameter has a tick-box (selected by default) which indicates whether the `RecipeExecutor` actor will run in Lazy mode or not. A full description of Lazy mode is provided in Sect. 6.2.4.
- The “Recipe Failure Mode” parameter has a pull-down menu allowing the user to specify the behaviour of the actor if the pipeline recipe fails. The available options are:
  - Stop: The actor issues an error message and the workflow stops.
  - Continue: The actor creates an empty output and the workflow continues.
  - Ask: The actor displays a pop-up window and asks the user whether he/she wants to continue or stop the workflow. This option is the default option.
- The set of parameters which start with “recipe param” and end with a number or a string correspond to the parameters of the relevant SINFONI pipeline recipe. By default in the `RecipeExecutor` actor, the pipeline recipe parameters are set to their pipeline default values. If you need to change the default parameter value for any pipeline recipe, then this is where you should edit the value. For more information on the SINFONI pipeline recipe parameters, the user should refer to the SINFONI pipeline user manual (Modigliani et al. 2013<sup>7</sup>).

The description of the remainder of the `RecipeExecutor` actor parameters are outside the scope of this tutorial, and the interested user is referred to the Reflex User Manual for further details (Forchì 2012). Any changes that you make in the “Edit parameters” window must be saved in the workflow by clicking the `Commit` button when you have finished to take effect. If you want to reuse the parameters you have to save the workflow with the saved parameters.

#### 6.2.4 Lazy Mode

By default, all recipe executor actors in a pipeline workflow are “Lazy Mode” enabled. This means that when the workflow attempts to execute such an actor, the actor will check whether the relevant pipeline recipe has already been executed with the same input files and with the same recipe parameters. If this is the case, then the actor will not execute the pipeline recipe, and instead it will simply broadcast the previously generated products to the output port. The purpose of the Lazy mode is therefore to minimise any reprocessing of data by avoiding data rereduction where it is not necessary.

One should note that the actor Lazy mode depends on the contents of the directory specified by

<sup>7</sup> Available at <ftp://ftp.eso.org/pub/dfs/pipelines/sinfoni/sinfo-pipeline-manual-16.0.pdf>

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	19 of 27

Table 6.2.0: The SINFONI pipeline actors and their contents


actor	recipe	description
Detector Linearity Computation	<code>sinfo_detlin</code>	determine detector linearity
Master Dark Computation	<code>sinfo_rec_mdark</code>	create master dark
Master Flat Computation	<code>sinfo_rec_mflat</code>	create master flat
Distortion Computation	<code>sinfo_rec_distortion</code>	compute detector’s distortions and slitlets distances
Wavelength Calibration	<code>sinfo_rec_wavecal</code>	determine wavelength calibration solution, wave map, slit pos table.
Object Cube Creation	<code>sinfo_rec_jitter</code>	reduce psf standard stars, flux standard starts and object data

`BOOKKEEPING_DIR` and the relevant FITS file checksums. Any modification to the directory contents and/or the file checksums will cause the corresponding actor when executed to run the pipeline recipe again, thereby rereducing the input data.

The forced rereduction of data at each execution may of course be desirable. To force a rereduction of all data for all `RecipeExecutor` actors in the workflow (i.e. to disable Lazy mode for the whole workflow), set the `EraseDirs` parameter under the “Global Parameters” area of the workflow canvas to `true`. This will then remove all previous results as well. To force a rereduction of data for any single `RecipeExecutor` actor in the workflow (which will be inside the relevant composite actor), right-click the `RecipeExecutor` actor, select `Configure Actor`, and uncheck the Lazy mode parameter tick-box in the “Edit parameters” window that is displayed.

## 6.3 Workflow Steps

### 6.3.1 Step 1: Data Organisation And Selection

On clicking the  button on the Reflex canvas, the workflow will highlight and execute the `Initialise` actor, which among other things will clear any previous reductions if required by the user (see Section 6.1).

1. The `DataOrganiser` (DO) is the first crucial component of a Reflex workflow. The DO takes as input `RAWDATA_DIR` and `CALIB_DATA_DIR` and it detects, classifies, and organises the files in these directories and any subdirectories. The output of the DO is a list of “DataSets”. A `DataSet` is a special Set of Files (SoF). A `DataSet` contains one or several science (or calibration) files that should be processed together, and all files needed to process these data. This includes any calibration files, and in turn files that are needed to process these calibrations. Note that different `DataSets` might overlap, i.e. some files might be included in more than one `DataSet`.

A `DataSet` lists three different pieces of information for each of its files, namely 1) the file name (including the path), 2) the file category, and 3) a string that is called the “purpose” of the file. The DO uses `OCA`<sup>8</sup> rules to find the files to include in a `DataSet`, as well as their categories and purposes. The file

<sup>8</sup>OCA stands for OrganisationClassificationAssociation and refers to rules, which allow to classify the raw data according to the

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	20 of 27

category identifies different types of files. A category could for example be `FLAT_LAMP`, `WAVE_LAMP` or `OBJECT_NODDING`. The purpose of a file identifies the reason why a file is included in a DataSet. The syntax is `action_1.action_2.action_3. . . . action_n`, where each `action_i` describes an intended processing step for this file. The actions are defined in the OCA rules and contain the recipe together with all file categories required to execute it (and predicted products in case of calibration data). For example, a workflow might include two actions `FLAT` and `WAVE_LAMP`. The former creates a master flat from raw flat frames, and the later creates (among other products) a wavelength calibration solution frame. The `WAVE_LAMP` action needs raw arc lamp frames and the master flat as input. In this case, these flats will have the purpose `FLATS.WAVE_LAMP`. The same DataSet might also include biases with a different purpose, e.g. `FLATS.OBJECT_NODDING`. Irrespective of their purpose the file category for all these biases will be `FLATS`.

2. Next the DataSet Chooser displays the DataSets available in the “Select Data Sets” window<sup>9</sup>, activating a vertical scroll bar on the right if necessary (see Figure 4.0.3). Sometimes you will want to reduce a subset of these DataSets rather than all DataSets, and for this you may individually select (or de-select) DataSets for processing using the tick boxes in the first column, and the buttons `Select All` and `Deselect All` at the bottom left.

You may also highlight a single DataSet in blue by clicking on the relevant line. If you subsequently click on `Inspect Highlighted`, then a “Select Frames” window will appear that lists the set of files that make up the highlighted DataSet including the full filename and path for each file, the file category (from the FITS header), and a selection tick box in the right column (see Figure 6.3.1). The tick boxes allow you to edit the set of files in the DataSet which is useful if it is known that a certain calibration frame is of poor quality (e.g. a poor raw flat-field frame). The list of files in the DataSet may also be saved to disk as an ASCII file by clicking on `Save As` and using the file browser that appears.

By clicking on the line corresponding to a particular file in the “Select Frames” window, the file will be highlighted in blue, and the file FITS header will be displayed in the text box on the right (see Figure 6.3.1), allowing a quick inspection of useful header keywords. If you then click on `Inspect`, the workflow will open the file in the selected FITS viewer application defined by the workflow parameter `FITS_VIEWER`.

To exit from the “Select Frames” window, click `Continue`, and to exit from the “Select DataSets” window, click either `Continue` in order to continue with the workflow reduction, or `Stop` in order to stop the workflow.

The categories and purposes of raw files are set by the DO, whereas the categories and purpose of products generated by recipes are set by the `RecipeExecutor` (see Sect. 6.2.3). The file categories are used by the `FitsRouter` to send files to particular processing steps or branches of the workflow (see below). The purpose is used by the `SofSplitter` to generate input SoFs for the `RecipeExecutor` and the results are collected by the `SofAccumulator`. Note that while the DO includes files into a DataSet for a reason, and records this reason as the “purpose” of the file, the workflow itself can use these files in a different manner. The `SofSplitter` and `SofAccumulator` accept several SoFs as simultaneous input. The `SofAccumulator`

---

contents of the header keywords, organise them in appropriate groups for processing, and associate the required calibration data for processing. They can be found in the directory `<install_dir>/share/esopipes/<pipeline-version>/reflex/`, carrying the extension `.oca`

<sup>9</sup>If you run the Data Organiser in Lazy Mode, changes in the Keywords to be displayed list will have no effect on the output shown in the DataSet Chooser.

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	21 of 27

creates a single output SoF from the inputs, whereas the `SofSplitter` creates a separate output SoF for each purpose.

### 6.3.2 Step 2: Recipe execution

Once the datasets to be reduced are selected, press the `Continue` button on the dataset organised window to proceed with the data reduction. The workflow will automatically execute the pipeline recipes and construct the `.sof` files to feed the pipeline recipes with. Each sof file will be saved in the `BOOKKEEPING_DIR` directory (and subdirectory within it), depending on the recipe it is associated to and the execution time. The pipeline parameters can be changed as shown in figure 6.2.2.

### 6.3.3 Step 3: Final products

Once a dataset is reduced (i.e. when the `sinfo_rec_jitter` recipe is terminated), a window containing the list of science product is popped out. Each file can be inspected with the selected fits viewer. Final science products will be stored in the `END_PRODUCTS_DIR`, and sorted by execution time and dataset identifier (i.e. the name of the science frame the dataset is for). Default names for the science products are: `<TARG name>AO_PERFORMANCE.fits`, `<TARG name>COADD_OBJ.fits`, `<TARG name>_ENC_ENERGY.fits`, `<TARG name>OBS_OBJ.fits`, and `<TARG name>STD_STAR_SPECTRA.fits`, and `<TARG name>SKY_M`. We refer the user to the SINFONI pipeline manual for the description of these files.

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	22 of 27

?

**recipe:**  
**mode:**  
**Lazy Mode:**  
**Recipe Failure Mode:**  
**Input Files Category:**  
**Output Files Category:**  
**File Purpose Processing:**  
**Allow empty inputs:**  
**Pause before execution:**  
**Pause after execution:**  
**Clear Products Dir:**  
**Clear Logs Dir:**  
**Clear Bookkeeping Dir:**  
**Products Dir:**  
**Logs Dir:**  
**Bookkeeping Dir:**  
**EsoRex default args:**  
**recipe\_param\_1:**  
**recipe\_param\_2:**  
**recipe\_param\_3:**  
**recipe\_param\_4:**  
**recipe\_param\_5:**  
**recipe\_param\_6:**  
**recipe\_param\_7:**  
**recipe\_param\_8:**  
**recipe\_param\_9:**  
**recipe\_param\_10:**  
**recipe\_param\_11:**  
**recipe\_param\_12:**  
**recipe\_param\_13:**  
**recipe\_param\_14:**  
**recipe\_param\_15:**  
**recipe\_param\_16:**  
**recipe\_param\_17:**  
**recipe\_param\_18:**  
**recipe\_param\_19:**  
**recipe\_param\_20:**  
**recipe\_param\_21:**  
**recipe\_param\_22:**  
**recipe\_param\_23:**  
**recipe\_param\_24:**

sinfo\_rec\_mflat

Run

☒

\$RecipeFailureMode

FLAT\_LAMP,BP\_MAP\_NL,REF\_BP\_MAP

MASTER\_BP\_MAP,BP\_MAP\_NO,MASTER\_FLAT\_LAMP

Strip last

☐

☐

☐

Never

Never

Never

\$TMP\_PRODUCTS\_DIR

Browse

\$LOGS\_DIR

Browse

\$BOOKKEEPING\_DIR

Browse

\$ESORexArgs

gen-overpar=true

lc-sw=false

lc-kappa=18

lc-filt-rad=3

product-density=2

bp\_norm-s\_factor=5

bp\_norm-method\_ind=1

bp\_norm-fct=10

bp\_norm-it=8

bp\_norm-lo\_rej=0.10000000000000001

bp\_norm-hi\_rej=0.10000000000000001

bp\_norm-llx=270

bp\_norm-illy=1000

bp\_norm-urx=310

bp\_norm-ury=1200

bp\_norm-thr\_ind=true

bp\_norm-mean\_fct=100

bp\_norm-min\_cut=0

bp\_norm-max\_cut=50000

lamp\_flats-lo\_rej=0.10000000000000001

lamp\_flats-hi\_rej=0.10000000000000001

lamp\_flats-interpol\_index=false

lamp\_flats-max\_rad=4

lamp\_flats-hard\_ind=false

Commit
Add
Remove
Restore Defaults
Preferences
Help
Cancel

Figure 6.2.2: The “Edit parameters” window for a typical RecipeExecutor actor, the sinfo\_rec\_mflat\_1 actor which runs the sinfo\_rec\_mflat pipeline recipe.

ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	23 of 27




Figure 6.3.1: The “Select Frames” window with a single file from the current Data Set highlighted in blue, and the corresponding FITS header displayed in the text box on the right. Hidden partially behind the “Select Frames” window is the “Select DataSets” window with the currently selected DataSet highlighted in blue.

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	24 of 27

## 7 Troubleshooting

In this section we describe some of the problems that may occur when reducing the SINFONI data with the ESOREX pipeline. For a more comprehensive description we refer the user to the SINFONI user manual (<http://www.eso.org/sci/software/pipelines/>).

### 1. Should I change the CALIB\_DATA\_DIR configuration?

This directory is setup automatically to point to the calibration database provided with the pipeline and in principle shouldn't be changed. However, if static calibration data are present in the RAWDATA\_DIR (e.g. calibrations are downloaded from the archive, or copied from ESO-DVD distribution), then you might have to set this directory equal to RAWDATA\_DIR (otherwise an obsolete static calibration file may be selected instead of the most appropriate one).



ESO	Reflex Sinfoni Tutorial	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	25 of 27

## 8 Frequently Asked Questions

- **Where are my intermediate pipeline products?** Intermediate pipeline products are stored in the directory `<TMP_PRODUCTS_DIR>` (defined on the workflow canvas) and organised further in directories by pipeline recipe.
- **Can I use different sets of bias frames to calibrate my flat frames and science data?** Yes. In fact this is what is currently implemented in the workflow(s). Each file in a DataSet has a purpose attached to it (Forchi (2012)). It is this purpose that is used by the workflow to send the correct set of bias frames to the recipes for flat frame combination and science frame reduction, which may or may not be the same set of bias frames in each case.
- **Can I launch Reflex from the command line?** Yes, use the command:

```
reflex -n <workflow_path>/<workflow>.xml
```

The `-n` option will set all the different options to Kepler and the workflows that avoid any graphical display (including pipeline interactive windows). Note that this mode is not fully supported, and the user should be aware that the execution prompt is not returned after the workflow finishes, and therefore Reflex must be manually killed.

- **How can I add new actors to an existing workflow?** You can drag and drop the actors in the menu on the left of the Reflex canvas. Under `Eso-reflex -> Workflow` you may find all the actors relevant for pipeline workflows, with the exception of the recipe executor. This actor must be manually instantiated using `Tools -> Instantiate Component`. Fill in the “Class name” field with `org.eso.RecipeExecutor` and in the pop-up window choose the required recipe from the pull-down menu. To connect the ports of the actor, click on the source port, holding down the left mouse button, and release the mouse button over the destination port. Please consult the Reflex User Manual (Forchi (2012)) for more information.
- **How can I broadcast a result to different subsequent actors?** If the output port is a multi-port (filled in white), then you may have several relations from the port. However, if the port is a single port (filled in black), then you may use the black diamond from the toolbar. Make a relation from the output port to the diamond. Then make relations from the input ports to the diamond. Please note that you cannot click to start a relation from the diamond itself. Please consult the Reflex User Manual (Forchi (2012)) for more information.
- **How can I run manually the recipes executed by Reflex?** If a user wants to re-run a recipe on the command line he/she has to go to the appropriate `reflex_book_keeping` directory, which is generally `reflex_book_keeping/<workflow>/<recipe_name>_<number>`. There, subdirectories exist with the time stamp of the recipe execution (e.g. `2013-01-25T12:33:53.926/`). If the user wants to re-execute the most recent processing he/she should go to the `latest` directory and then execute the script `cmdline.txt`. Alternatively, to ensure that the path to `esorex` is the correct one, the user can execute

```
ESOREX_CONFIG="INSTALL_DIR/etc/esorex.rc"
INSTALL_DIR/bin/esorex --recipe-config=<recipe>.rc <recipe> data.sof
```

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	26 of <a href="#">27</a>

where `INSTALL_DIR` is the directory where Reflex and the pipelines were installed. If the user knows the name of the input raw files for the recipe, the correct directory among the many time stamps can be found via `grep <raw_file> */data.sof`. Afterwards the procedure is the same as before. The products will appear in the directory from which the recipe is called, and not in the `reflex_tmp_products` or `reflex_end_products` directory, and they will not be renamed.

<b>ESO</b>	<b>Reflex Sinfoni Tutorial</b>	Doc:	VLT-MAN-ESO-19500-XXXX
		Issue:	Issue 1.0
		Date:	Date 2013-10-21
		Page:	27 of 27

Forchì V., 2012, Reflex User Manual, VLT-MAN-ESO-19000-5037, Issue 0.7,  
<ftp://ftp.eso.org/pub/dfs/reflex/ReflexUserManual-3.1.pdf> 15, 18, 25

SINFONI Pipeline User Manual, VLT-MAN-ESO-19500-3600, Issue 16.0 18

The SINFONI Pipeline, proceedings ADA-2006, <http://www.eso.org/sci/software/pipelines/>.